

COPY OF WATER, HEALTH AND SANITATION CERTIFICATE

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 389

Date: 03.05.2023

It is certified that an inspection team headed by Sh.Sukhvir Singh, J E from Water Supply and Sanitation Sub Division, **Shaheed Bhagat Singh Public High School, VPO Bela, Tehsil Chamkaur Sahib, Distt. Rupnagar (Punjab)** on 24.04.2023 and found that **Shaheed Bhagat Singh Public High School, VPO Bela, Tehsil Chamkaur Sahib, Distt. Rupnagar (Punjab)**, has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the State Govt.

The above valid for a period of one year i.e 03.05.2023 to 02.05.2024.



Senior Medical Officer
I/C C.H.C. Chamkaur Sahib
Distt. Roopnagar

Senior Medical Officer,
C.H.C., Chamkaur Sahib,
District Roopnagar

To,

The Principal,
Shaheed Bhagat Singh Public High School,
VPO Bela, Tehsil Chamkaur Sahib,
Distt. Rupnagar (Punjab)

ATTESTED
NOTARY PUBLIC
DHURI (PB.) INDIA
25 MAY 2023

Principal
Shaheed Bhagat Singh
Public School, Bela (Ropar)



Sandeep Saini
Director
Shaheed Bhagat Singh
Public School, Bela, Ropar

ਸਟੇਟ ਪਬਲਿਕ ਹੈਲਥ ਲਬੋਰਟਰੀ ਪੰਜਾਬ, ਖਰੜ।
State Public Health Laboratory Punjab, Kharar
(Email id- sphlreports@gmail.com)

ਸੇਵਾ ਵਿਖੇ,

ਸਿਵਲ ਸਰਜਨ, ਰੂਪਨਗਰ


ਵਿਸ਼ਾ :- ਪਾਣੀ ਦੇ ਸੈਂਪਲਾਂ ਦੀ ਬੈਕਟੀਰੀਅਲ ਅਤੇ ਕੈਮੀਕਲ ਟੈਸਟਾਂ ਦੇ ਅਧਾਰ ਤੇ ਵਿਸ਼ਲੇਸ਼ਣ ਰਿਪੋਰਟ।

ਆਪ ਵਲੋਂ ਮਿਤੀ 03-06-2026 ਨੂੰ ਭੇਜੇ ਗਏ ਪਾਣੀ ਦੇ ਸੈਂਪਲਾਂ ਦੀ ਵਿਸ਼ਲੇਸ਼ਣ ਰਿਪੋਰਟ ਇਸ ਲਬੋਰਟਰੀ ਵਿਚ ਕੀਤੇ ਗਏ ਟੈਸਟਾਂ (with respect to BIS guidelines ISO 10500: Drinking water specifications-2012) ਦੇ ਅਧਾਰ ਤੇ ਹੇਠ ਅਨੁਸਾਰ ਹੈ।

ਲੜੀ ਨੰ	ਲੇਬ ਨੰ	ਸੈਂਪਲਾਂ ਦਾ ਵੇਰਵਾ SMO SDH Chamkaur Sahib, RoopNagar	Urban/ Rural	ਪੀਣ ਯੋਗ/ ਅਯੋਗ	ਅਯੋਗ ਹੋਣ ਦੇ ਕਾਰਣ ਜਾਂ ਹੋਰ ਟਿਪਣੀ
1	1527	Shaheed Bhagat Singh Public School, Bela, Chamkaur Sahib, RoopNagar (R.O)	Rural	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
2	1528	A.A.K Fatehpur, Chamkaur Sahib, RoopNagar (Tap Water)	Rural	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
3	1529	A.A.K Khokhar, Chamkaur Sahib, RoopNagar (Tap Water)	Rural	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
4	1530	Anganwadi Centre Vill- Khokhar, Chamkaur Sahib, RoopNagar (Tap Water)	Rural	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0

ਉਪਰੋਕਤ ਰਿਪੋਰਟ ਹੇਠ ਲਿਖੇ ਕੈਮੀਕਲ ਟੈਸਟਾਂ ਅਤੇ ਬੈਕਟੀਰੀਅਲ ਟੈਸਟਾਂ ਦੀ Acceptable Limit ਦੇ ਅਨੁਸਾਰ ਦਿੱਤੀ ਗਈ ਹੈ।

BIS guidelines Drinking water specifications - (IS 10500:1991/2003/2012)	REQUIREMENT (Acceptable Limit)	Permissible Limit in Absence of Alternate Source
TDS	500	2000
PH	6.5-8.5	No relaxation
Calcium	75	200
Chloride	250	1000
Fluoride	1.0	1.5
Total hardness	200	600
Free residual chlorine	0.2	1.0
Total Coliform Bacteria/100 ml	The Requirement is Coliform Bacteria Should not be Detectable in 100ml Sample.	


5/6/26
ਬੈਕਟੀਰੀਆਲੋਜਿਸਟ
ਇਹ: ਸਟੇਟ ਪਬਲਿਕ ਹੈਲਥ ਲਬੋਰਟਰੀ ਪੰਜਾਬ, ਖਰੜ।